



# MADHAV INSTITUTE OF TECHNOLOGY & SCIENCE, GWALIOR

(A Govt. Aided UGC Autonomous & NAAC Accredited Institute Affiliated to RGPV, Bhopal, M.P.)

Gola ka Mandir, Gwalior (M.P.)- 474 005, INDIA

Ph.: +91-751-2409300, e-mail: director@mitsgwalior.in, website: www.mitsgwalior.in

## TESTING / CONSULTANCY REPORT

Civil/MKT/PS/Env.Engg.Lab./TR No. 325/ ~~10~~. Hologram No 706780/1875 Date: 01/09/23

To,

To,  
Rishi Galav Public School,  
B-Block, D.D. Nagar, Morar,  
Gwalior (MP) - 474005  
Email ID : [rgps.gwalior@gmail.com](mailto:rgps.gwalior@gmail.com)  
Phone No. : 0751-2479479, 3550040



Ref. No. : RGPS/1030113/23, Dated 08.08.2023

Sub: Site inspection & Testing of Water Sample for drinking purpose.

Dear Sir,

Kindly find enclosed herewith the Water Quality Test report and Safe drinking water and sanitary condition certificate for your Institution.

- Testing and visiting charge of Rs. 8214/- deposited by Transaction Ref. No. 322811163510 dated 16.08.2023.
- Sample received on 10-08-2023.
- Testing date/Report generated on: 11-08-2023/23-08-2023.
- Site visit date/Report generated on 12.08.2023/23.08.2023

*Prachi Singh*  
Dr. Prachi Singh  
Asst. Professor

*M.K. Trivedi*  
Dr. M.K. Trivedi  
(H.C.E.D.)


### Forwarded:

This Testing / Consultancy report is forwarded on the recommendations of the Department Responsibility of Test/Consultancy Report lies with the concerning department.

Testing/Consultancy Amount Paid
Rs. 8214/-
Charity No. 32281163510 / 16.08.23
Date 16.8.23
Finance cum Accounts Officer

DIRECTOR

*[Signature]*  
Manager  
Rishi Galav Public School  
Gwalior



075

Book No.: MITS TCR/XXXX  
*[Signature]* 29/08/2023

Sr. No.: 2022 .....





# MADHAV INSTITUTE OF TECHNOLOGY & SCIENCE, GWALIOR

(A Govt. Aided UGC Autonomous & NAAC Accredited Institute Affiliated to RGPV, Bhopal, M.P.)

Gola ka Mandir, Gwalior (M.P.)- 474 005, INDIA

Ph.: +91-751-2409300, e-mail: director@mitsgwalior.in, website: www.mitsgwalior.in

## TESTING / CONSULTANCY REPORT

Civil/MKT/PS/Env.Engg.Lab./TR No. 325/No. Ref. 2010 from TO 6180 Date:

To,  
Rishi Galav Public School,  
B-Block, D.D. Nagar, Morar,  
Gwalior (MP) - 474005  
Email ID : rgps.gwalior@gmail.com  
Phone No. : 0751-2479479, 3550040

MITS Dispatch

Ref. No. : RGPS/1030113/23, Dated 08.08.2023  
Sub. : Testing of Water Treated Sample for drinking purpose.

Dear Sir,

Please find herewith the test report of the sealed Treated water sample sent by you vide above mentioned reference & subject.

### TESTING REPORT

S. No.	Parameters/Tests	Laboratory Results
1	Temperature	25.2°C
2	Turbidity	Nil
3	Colour	Absent
4	Odour	Un-objectionable
5	Taste	Un-objectionable
6	pH Value	6.92
7	Acidity	26 mg/l as CaCO <sub>3</sub>
8	Alkalinity	60 mg/l as CaCO <sub>3</sub>
9	Total Solids	122 mg/l
10	Dissolved Solids	122 mg/l
11	Suspended Solids	Nil
12	Chlorides(Cl <sup>-</sup> )	70 mg/l
13	Hardness	90 mg/l as CaCO <sub>3</sub>
14	D.O.	6.2 mg/l

### Remarks:

- The above tested Parameters of water sample complies with the drinking water standards laid down in IS:10500-2012. Hence it can be commented that Water Sample is safe for drinking purpose only on the above tested parameters.

Dr. Prachi Singh  
Asst. Professor

### Forwarded:


This Testing / Consultancy report is forwarded on the recommendations of the Department Responsibility of Test / Consultancy Report lies with the concerning department.



Dr. M.K. Trivedi  
(H.C.E.D.)

DIRECTOR





# MADHAV INSTITUTE OF TECHNOLOGY & SCIENCE, GWALIOR

(A Govt. Aided UGC Autonomous & NAAC Accredited Institute Affiliated to RGPV, Bhopal, M.P.)

Gola ka Mandir, Gwalior (M.P.)- 474 005, INDIA

Ph.: +91-751-2409300, e-mail: director@mitsgwalior.in, website: www.mitsgwalior.in

## TESTING / CONSULTANCY REPORT

Civil/MKT/PS/Env.Engg.Lab./TR No. 325/ Ref. Hologram No To 6780

Date:

To,  
Rishi Galav Public School,  
B-Block, D.D. Nagar, Morar,  
Gwalior (MP) - 474005  
Email ID : [rgps.gwalior@gmail.com](mailto:rgps.gwalior@gmail.com)  
Phone No. : 0751-2479479, 3550040

### SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Dr. Prachi Singh, Assistant Professor from Civil Engineering Department, MITS, Gwalior inspected the Rishi Galav Public School, B-Block, D.D. Nagar, Morar, Gwalior on 12.08.2023 and found that the Rishi Galav Public School, B-Block, D.D. Nagar, Morar, Gwalior has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T. Govt.

The above certificate is valid for a period of 01 year (Aug. 2023 to July 2024)

#### Remarks :

This is as per the physical visit conducted at school on 12/08/2023 and water quality testing conducted at our Institute, the water quality test report for the same is annexed with this certificate.

*Prachi*  
12/08/23  
Dr. Prachi Singh  
Asst. Professor

*M.K. Trivedi*  
Dr. M.K. Trivedi  
(H.C.E.D.)

*[Signature]*  
Manager  
Rishi Galav Public School  
Gwalior



Book No.: MITS TCR/ XXXX


Sr. No.: 2022 ..... 074

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 325/24

Dated: 15/02/24

It is certified an inspection team headed by Shailendra Dixit (Name of Officers with designation) from Water works (Name of Department/Office) inspected the Rishi Galav Public School on 09/02/24 (date of inspection) and found that the school has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. The above is valid for a period of three years.



Signature with Seal :

Name:

Designation:

Name & Address of the Office/Department:

To,

Rishi Galav Pubic School  
DD Nagar, Morar, Gwalior